



# ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

**THE MUNICIPAL CORPORATION OF THE CITY OF THANE**

Ref/T.M.C./CFO/M - 760

Date - 10/01/2024

## FIRE SAFETY CERTIFICATE

Certified that the **D.A.V. Public School** (name of the building or Premises) at **Survey No. 157, Plot No.31, Tulsidham, Thane (w) – 400610.** (address) Comprised of **Ground Floor + 5th upper Floor** owned / occupied by **Dayanand Anglo Vedic College Trust and Management Society, New Delhi.** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 02/01/2024 (date of inspection) in the presence of Nitin Mohan Patil Save Fire Protection Engineers (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes **Nur. to X (X /XII)** With effect from **09.01.2024** for a period of **One year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Riser – 100mm	- Yes	8. Inlet Breeching	- Yes
2. Hose Reel	- Yes	9. Booster Pump	- Yes
3. Hose Box	- Yes	10. Main Electric Pump	- Yes
4. Hose Pipe	- Yes	11. ABC Fire Extinguisher 4Kg Cap.	- Yes
5. Fire Fighting Tank	- Yes	12. ABC Fire Extinguisher 5Kg Cap.	- Yes
6. Courtyard Hydrant	- Yes	13. ABC Fire Extinguisher 6Kg Cap	- Yes
7. Siamese Connection	- Yes	14. Fire Alarm / Detection System	- Yes

Issued on 09 /01/ 2024 (date of issue) at Thane (place) by

Signature with seal: \_\_\_\_\_

Name

: Mr. Girish. M. Zalke

Designation

: Chief Fire Officer, Thane

Name & Address of Department/ Office

: Chief Fire Officer, Thane  
Municipal Fire Brigade, Thane.

To

**D.A.V. Public School**

**Survey No. 157, Plot No.31,**

**Tulsidham, Thane (w) – 400610.**

(Name & Address of the Institution)

### ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to **negligence of any fire safety norms laid by state government.**

**This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.**

(Name and designation of the authorized signatory)