



**ठाणे महानगरपालिका**  
**THE MUNICIPAL CORPORATION OF THE CITY OF THANE**  
**प्रदूषण नियंत्रण कक्ष**  
**POLLUTION CONTROL CELL**



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,  
 चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6<sup>th</sup> November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 1193  
 Sample No. : M722

Date : 24 February 2021

**Water Analysis Report**

TMC/PCC/20/RO

Name Of the Organisation : M/S DAV Public School

Address : Tulasidham; Thane (W)

E\_mail ID : davthane@yahoo.co.in

Date of receiving Sample : 23 February 2021

Sample Collected by : Akash Jagtap

Type of Water Sample : Storage Drinking (4th Sample)

| Parameters                    | Results | Limits as per IS 10500 |
|-------------------------------|---------|------------------------|
| pH                            | 7.30    | 6.5 - 8.5              |
| Free Residual Chlorine        | Nil     | 1 ppm                  |
| Turbidity                     | 2.0     | 5 NTU                  |
| Chloride                      | 40.0    | 250 mg/L               |
| Total Hardness                | 75.0    | 200 mg/L               |
| Total Coliform Bacteria (MPN) | 0.00    | 0/100 mL               |
| F-Coli                        | Absent  | 0/100 mL               |
| E-Coli                        | Absent  | 0/100 mL               |

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

24-Feb-21

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

24-Feb-21

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (4th Sample) Water sample received to our Vakratunda Laboratory on 23/2/2021. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/HQ/PL/0000846/17-18 dated 26.03.2018

This Report has been Signature Digitally.

**PRINCIPAL**  
**D.A.V. PUBLIC SCHOOL**  
**THANE**

**Manish Chopra**  
**MANAGER**  
**D. A. V. Public School,**  
**Tulasidham**  
**Thane (W.)-400 007.**



## ठाणे महानगरपालिका, ठाणे

महानगरपालिका भवन, कै.जे.टी.एल. अल्मेडा वकील मार्ग, चंदनवाडी, पाचपाखाडी, ठाणे-४०० ६०२

**THE MUNICIPAL CORPORATION OF THE CITY OF THANE**

दुरध्वनी :- ०२२-२५४९९०५३  
०२२-२५४२५६७७

dmcswm@thanecity.gov.in

संदर्भ क्र. डीएमसी/

TMC/SWM/DMC-362

दिनांक 15/11/2024

### TO WHOMSOEVER IT MAY CONCERN

This is to Certify that, D.A.V. Public School, Tulshidham, Thane (W) has Provided reasonably well Sanitary measures prescribed for registered schools under the Indian Public Health Standards, for Air, Water and Food Sanitation, Toilets, Urinals and Cleanliness of the Premise for the year 2021-22.

It would be obligatory for the management of the school maintain these Sanitary precautions according to public health standards.

Dy. Municipal Commissioner  
Solid Waste Management  
Thane Municipal Corporation, Thane.

PRINCIPAL  
D.A.V. PUBLIC SCHOOL  
THANE

MANAGER  
D. A. V. Public School,  
Tulshidham.  
Thane (W.)-400 607.