	कार्यकारी अभियंता यांचे कार्यालय, सा. बां. विभाग क्र.१, ठाणे सा. बां. विभाग आवार, स्टेशन रोड, ठाणे (प.)- ४०० ६०१.	
 - www.mahapwd.com	 - thane1.ee@mahapwd.com	① २५३६९२९३
जा.क्र.साबांवि.क्र.१/रेशा/इमारत सुरक्षितता/१०६४		दिनांक : १६/०२/२०२२

प्रति,
 प्राचार्य,
 डी.ए.व्ही. पब्लिक स्कूल,
 सी.बी.एस.ई. न्यू जनरेशन स्कूल
 तुलसीधाम ठाणे प.

विषय - इमारत सुरक्षित असल्याबाबतचा दाखला देणेबाबत.
 डी.ए.व्ही. पब्लिक स्कूल, सी.बी.एस.ई. न्यू जनरेशन स्कूल तुलसीधाम ठाणे प.

संदर्भ - १. प्राचार्य, डी.ए.व्ही. पब्लिक स्कूल, सी.बी.एस.ई. न्यू जनरेशन स्कूल तुलसीधाम ठाणे प. यांचे पत्र No.DAV/Thane/2021-22/254, दि. ०३/१२/२०२१.
 २. सहाय्यक अभियंता श्रे.१, सा. बां. उपविभाग क्र. २, ठाणे (प.) यांचे पत्र जा.क्र. उपवि/ठाणे-१/प्रशा/१३२, दि. १५/०२/२०२२.

वरील संदर्भीय विषयानुसार आपण सादर केलेल्या आवेदन पत्रानुसार आपल्या डी.ए.व्ही. कॉलेज मॅनेजिंग कमिटी संचलित डी.ए.व्ही. पब्लिक स्कूल, सी.बी.एस.ई. न्यू जनरेशन स्कूल तुलसीधाम ठाणे प. येथील शालेय इमारतीची या विभागामार्फत सहाय्यक अभियंता श्रे.१, सा. बां. उपविभाग क्र. २, ठाणे (प.) यांनी दि. ३१/०१/२०२२ रोजी प्रत्यक्ष पाहणी केली आहे.

आपल्या संस्थेने प्रस्तुत प्रकरणी आवश्यक ती कागदपत्रे व उप विभागीय अभियंता, सा. बां. उपविभाग क्र. ३, ठाणे यांनी सादर केलेल्या पाहणी अहवालाच्या आधारे तसेच प्रमाणपत्रातील अटीवर शालेय इमारत सुरक्षित असल्याबाबतचे प्रमाणपत्र आपल्या माहितीसाठी व आवश्यक त्या पुढील कार्यवाहीसाठी देण्यात येत आहे. कृपया त्याची पोहोच द्यावी.

स्थापत्य कामात बदल करावयाचे झाल्यास याबाबत संबंधित प्राधिकरणाकडून सर्व परवानगी प्राप्त करून घेण्याची जबाबदारी आपल्या शाळेची राहिल.

सोबत : इमारत सुरक्षितता प्रमाणपत्र.

कार्यकारी अभियंता
सा. बां. विभाग क्र.१
ठाणे

प्रत : सहाय्यक अभियंता श्रे.१, सा. बां. उपविभाग क्र. २, ठाणे यांना संदर्भ पत्र क्र.२ चे अनुषंगाने माहितीसाठी रवाना.

BUILDING STABILITY CERTIFICATE.

Certified that the Educational building belonging to "D. A. V. Public School, CBSE New Generation School, Tulsidham, Tal & Dist. Thane (W.) - 400 610" has been inspected by this office on Dt.:- 31/01/2022. At the time of inspection, the educational building seems structurally safe, sound, stable and enough to bear the existing live load. The building is used for school purpose as on date, except in the case of the natural calamity.


It is also certified that the following general terms and conditions may be full filled by the management in the stipulated period.

- 1) All Urinals & Toilets blocks should be clean and maintain it properly.
- 2) Fire fighting equipments shall be suitably located and clearly marked, and the equipments shall be refilled and renewed time to time periodically.
- 3) There should be sufficient natural light and ventilaltion every time.
- 4) Essential requirements for electrical installation in the building to ensure sufficient use of electricity including safety from fire and shock.
- 5) The necessary N.O.C. or permissions from the concerned competent authorities such as Fire Brigade Certificate from T.M.C., etc. should be got by the management.

The necessary inspection fees Rs.1000/- (Rupees One thousand only) paid by the Management vide D.R. No.970178 dated:- 16/12/2021.

This certificate is valid for 1 year from the date of issue and it will be renewed before the expiry of the stipulated period.

Counter Signature


Assistant Engineer Gr-I
P. W. Sub-Division - 2
Thane


Executive Engineer
P. W. Division No.1
Thane