

दुरध्वनी : २५३३९२९९

२५३३९५९०



## ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 1009

Date - 11/03/2025

### FIRE SAFETY CERTIFICATE

Certified that the D.A.V. Public School (name of the building or Premises) at Survey No. 157, Plot No.31, Tulsidham, Thane (w) - 400610. (address) Comprised of Ground Floor + 5th upper Floor owned / occupied by Dayanand Anglo Vedic College Trust and Management Society, New Delhi. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 07/03/2025 (date of inspection) in the presence of Mr. Machindra G. Devkar, (MD ENTERPRISES) (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes Nur. to X (X /XII) With effect from 11.03.2025 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- |                         |       |  |       |
|-------------------------|-------|--|-------|
| 1. Main Electric Panel  | - Yes | 8. Courtyard Hydrant                   | - Yes |
| 2. Riser- 150MM         | - Yes | 9. Hose Box With RRL                   | - Yes |
| 3. Main Electric Pump   | - Yes | 10. Sprinkler                          | - Yes |
| 4. Jockey Pump          | - Yes | 11. Smoke Detector                     | - Yes |
| 5. Booster Pump         | - Yes | 12. ABC Fire Extinguisher 5Kg to 10Kg  | - Yes |
| 6. Hose Reel Drum 30Mtr | - Yes | 13. DCP Fire Extinguisher 5Kg to 10Kg. | - Yes |
| 7. Single Hydrant Valve | - Yes | 14. CO2 Fire Extinguisher 4.5 Kg.      | - Yes |

Issued on 11 /03/ 2025 (date of issue) at Thane (place) by



Signature with seal: \_\_\_\_\_

Name : Mr. Girish. M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane  
Municipal Fire Brigade, Thane.

To

D.A.V. Public School  
Survey No. 157, Plot No.31,  
Tulsidham, Thane (w) - 400610.  
(Name & Address of the Institution)

### ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)