



ठाणे महानगरपालिका

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष

POLLUTION CONTROL CELL



E-mail : pccmtmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 707
Sample No. : S228

Date : 17 June 2026

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S DAV Public School

Address : Tulshidham,Thane

E_mail ID : davthane@yahoo.co.in

Date of receiving Sample : 16 June 2026

Sample Collected by : Om Paralkar

Type of Water Sample : Storage Drinking (2nd Sample)

Parameters	Results	Limits as per IS 10500
pH	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	1.0	5 NTU
Chloride	20.0	250 mg/L
Total Hardness	35.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

17-Jun-26

Sanchita S. Kadlak

Thane Municipal Corporation, Thane

Authorised by

17-Jun-26

Nirmitee N. Salgaonkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (2nd Sample) Water sample received to our Vakratunda Laboratory on 16/6/2026. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 1326/- vide Receipt No.TMC/OL/PLC/0000014/26-27 dated 30.04.2026

This Report Is Digitally Signed And Approved.