



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 424
Sample No. : 0171

Date : 24 May 2022

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S DAV Public School

Address : Tulasidham; Thane (W)

E_mail ID : davthane@yahoo.co.in

Date of receiving Sample : 23 May 2022

Sample Collected by : Akash Jagtap

Type of Water Sample : Storage Drinking (3rd sample)

Parameters	Results	Limits as per IS 10500
pH	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	3.0	5 NTU
Chloride	30.0	250 mg/L
Total Hardness	56.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

24-May-22

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

24-May-22

Omsatashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (3rd sample) Water sample received to our Vakratunda Laboratory on 23/5/2022. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/LOS/PLC/000085/21-22 dated 25.08.2021

This Report has been Signature Digitally.

PRINCIPAL
D.A.V. PUBLIC SCHOOL
THANE

Hakim Croor
MANAGER
D. A. V. Public School,
Tulasidham.
Thane (W.)-400 607.



ठाणे महानगरपालिका, ठाणे

महानगरपालिका भवन, कै.जे.टी.एल. अल्मेडा वकील मार्ग, चंदनवाडी, पाचपाखाडी, ठाणे-४०० ६०२

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

dmcswm@thanecity.gov.in

दिनांक 15/11/2021

संदर्भ क्र.अमसा/
TMC/SWM/DMC-362

TO WHOMSOEVER IT MAY CONCERN

This is to Certify that, D.A.V. Public School, Tulshidham, Thane (W) has Provided reasonably well Sanitary measures prescribed for registered schools under the Indian Public Health Standards, for Air, Water and Food Sanitation, Toilets, Urinals and Cleanliness of the Premise for the year 2021-22.

It would be obligatory for the management of the school maintain these Sanitary precautions according to public health standards.

Dy. Municipal Commissioner
Solid Waste Management
Thane Municipal Corporation, Thane.

PRINCIPAL
D.A.V. PUBLIC SCHOOL
THANE

Attest
Maksh Chople
MANAGER
D. A. V. Public School,
Tulsidham
Thane (W.)-400 602